



NATIONAL TYPE EVALUATION PROGRAM

Certificate of Conformance

for Weighing and Measuring Devices

For:

Wheel-Load Weigher
Digital Electronic
Model: PT300
 n_{max} : 400 e_{min} : 20 kg / 50 lb
Capacity: 20,000 x 50 lb * see below
Platform: 12 inches x 12 inches * see below

Class III

Submitted By:

Intercomp Corporation
3839 County Road 116
Medina, MN 55340
Tele: (763) 476-2531
Fax: (763) 476-2613
Contact: Matt Young
Email: matt@intercompco.com
Web site: www.intercompcompany.com

Standard Features and Options

- *Optional Capacities: 10 000 x 50 lb
 10 000 x 20 kg
 5 000 x 20 kg
- *Optional platform sizes: 10 inches x 11 inches, or 10 inches x 14 inches

- Semi-Automatic Zero
- Automatic Zero Tracking (AZT)
- Liquid Crystal Display
- Pound/Kilogram Conversion
- Solar Battery Recharging
- Wireless Communication

Load cells used: (2) PT300-03

Note: A specifically designed pad provided by the manufacturer was used to distribute the load and simulate pneumatic tire loads during laboratory testing.

Temperature Range: -10 °C to 40 °C (14 °F to 104 °F)

This device was evaluated under the National Type Evaluation Program and was found to comply with the applicable technical requirements of "NIST Handbook 44: Specifications, Tolerances and Other Technical Requirements for Weighing and Measuring Devices." Evaluation results and device characteristics necessary for inspection and use in commerce are on the following pages.

Ronald Hayes
Chairman, NCWM, Inc.

John Gaccione
Committee Chair, National Type Evaluation Program Committee
Issued: November 3, 2014

1135 M Street, Suite 110 / Lincoln, Nebraska 68508

The National Conference on Weights and Measures (NCWM) does not approve, recommend or endorse any proprietary product or material, either as a single item or as a class or group. Results shall not be used in advertising or sales promotion to indicate explicit or implicit endorsement of the product or material by the NCWM.



Intercomp Corporation
Wheel-Load Weigher / PT300

Application: For use in law enforcement as a wheel-load weigher. Special application is noted on the identification plate, marked "Wheel Load Weigher".

Identification: Identification information is marked on the display face. Serial number is stamped on the front of the base.

Sealing: A lead and wire security seal is to be threaded through the two screws on the right front corner of the scale that fasten the cover of the weight display.

Test Conditions: This certificate supersedes Certificate of Conformance 90-106PA2 and is issued to add a solar battery recharging option and wireless communication capability. 2 PT300 wheel load weighers interfaced with an Intercomp RFX indicator (NTEP CC 12-118), and a specifically designed pad measuring 8 inches x 8 inches to distribute the load and simulate pneumatic tire loads during laboratory testing were submitted for evaluation. Several increasing test using 19 900 lb of known test weights at 3.85 VDC to 6.6 VDC and return to zero tests were performed. The wireless checklist found in NCWM Publication 14 was used to check for compliance with wireless requirements. No other testing was deemed necessary per information provided by the manufacture. Previous test conditions are listed below for reference.

Certificate of Conformance 90-106PA2: This certificate supersedes Certificate of Conformance 90-106PA1 and is issued without testing to clarify the fact that a specifically designed pad provided by the manufacturer was used to distribute the load and simulate pneumatic tire loads during laboratory testing.

Certificate of Conformance 90-106PA1: This certificate supersedes Certificate of Conformance 90-106P and based on information provided by the manufacturer, is issued without testing to add a smaller capacity in lb units and to add the equivalent capacities and division sizes in kg units. Smaller platform sizes were also added to this Certificate without additional testing.

Certificate of Conformance 90-106P: Two wheel-load weighers were tested initially in the laboratory using 20,000 lb of known test weights. Several increasing/decreasing load tests were performed on the scales both individually and in pairs. The scales were tested in an out-of-level condition using 18,900 lb of test weight. The scales were tested over a temperature range of -10 to 40°C (14-104°F). The zero change with temperature was also tested. The results of the evaluation indicate the wheel-load weighers comply with the applicable requirements of Handbook 44.

This certificate is issued based upon data provided by the manufacturer and test data collected in an NTEP lab.

Evaluated By: B. Badenhop, L. Rine & J. Truex (OH) 90-106P; W. West (OH) 90-106PA1; T. Buck, D. Walker (OH) 90-106PA3

Type Evaluation Criteria Used: *NIST Handbook 44 Specifications, Tolerances, and Other Technical Requirements for Weighing and Measuring Devices*, 2014 Edition. *NCWM Publication 14 Measuring Devices*, 2014 Edition.


Conclusion: The results of the evaluations and information provided by the manufacturer indicate the devices comply with applicable requirements.

Information Reviewed By: S. Patoray, L. Bernetich (NCWM) 90-106PA1; J. Truex (NCWM) 90-106PA2, 90-106PA3



Intercomp Corporation
Wheel-Load Weigher / PT300

Examples of Device:



PT300 with solar battery charger

